

Three Phase Fault Analysis with Auto Reset for Temporary Fault and Permanent Trip for Permanent FaultMahesh Gauttam¹, Madhuram², Neha Bhagora³, Moh. Danish⁴, Ravi Parsoya⁵

B.Tech scholar, Department of Electrical

Arya Institute of Engineering & Technology, Kookas, Jaipur.

Abstract

The project develops an automatic tripping mechanism for the three-phase transmission system. In the event of a temporary fault, the output of the project resets while it acquires permanent trip condition in case of a permanent fault. There can occur several failures in a three-phase supply system that provides power to industrial and domestic consumers. These failures are results of some faults which may be temporary or permanent in nature. Due to these faults, the power system may suffer considerable damage. This can lead to disturbance in power supply and may cause a standstill to various industries linked to the system. In a three phase power system, these faults are classified as LG (Line to Ground), LL (Line to Line), 3L (Three lines). This system can overcome such problem which by sensing the fault automatically and disconnects the system from the supply so that large scale damage to the system equipment can be avoided. The system automatically differentiates between a temporary disturbance and a permanent fault and appropriately cuts the supply for a short duration or long respectively.

Keyword: Temporary Fault, Permanent Fault, LG, LL and 3L Faults, Three-Phase System**Introduction**

A fault in a power system can be referred to any abnormality in the electric current flowing in it. For example, if the current is interrupted by some failure in the circuit, the resulting fault is an open circuit fault. If the current in the circuit bypasses the normal load, it results in a short circuit fault. In a threephase system, the fault may occur between one or more phase and ground or only between phases of the system. Generally, protective devices are used in transmission systems to detect fault conditions and result in operation of circuit breakers or isolators that help in limiting the damage due to the failure.

Classification of faults

Transient faults: In a system, if a fault diminishes when power is disconnected for a short period of time and then restored, the fault is referred as a transient fault. A transient fault may also be an insulation fault that temporarily affects a device's dielectric properties. Transient faults may be caused due to momentary tree contact, animal contact, lightning strike, etc.

Persistent faults: Faults that do not diminish when power is disconnected and restored are called persistent faults. Such faults generally occur due to mechanical damage to the cable or other equipment of the system.

Symmetric faults: In a three-phase system, if a fault affects all three phases equally, it is called a symmetric or a balanced fault. Generally symmetric faults constitute about 5% of the total faults.

Asymmetric fault: An unbalanced fault or asymmetric fault results in unequal effect of fault on each of the three phases. Asymmetric faults are further classified as LL or Line to Line fault, LG or Line to Ground fault and LLG or Double Line to Ground fault.

- LL fault is a short circuit between two lines, caused by ionization of air, or when lines come into physical contact, for example due to a broken insulator.
- LG Fault is a short circuit between one line and ground due to physical contact caused by lightning or storm.
- LLG fault occurs when two lines come in contact with the ground and each other. This is mainly caused by storm damage.

Working with block diagram

Working

The project uses 6 numbers step-down transformers for handling the entire circuit under low voltage conditions of 12v only to test the 3 phase fault analysis. The primaries of 3 transformers are connected to a 3 phase supply in star configuration, while the secondary of the same is also connected in star configuration. The other set of 3 transformers with its primary connected in star to 3 phase have their secondaries connected in Delta configuration. The outputs of all the 6 transformers are rectified and filtered individually and are given to 6 relay coils. 6 push buttons, every button connected across the relay coil is meant to create a fault condition either at star i.e. LL Fault or 3L Fault. The NC contacts of all the relays are made parallel while all the common points are grounded. The parallel connected points of NC are given to pin2 through a resistor R5 to a 555 timer i.e. wired in monostable mode.




Figure 1: Block Diagram of Three Phase Fault Analysis

Hardware working model of proposed analysis is given below:




Figure 2: Image of Hardware

Operating procedure

The board is powered from a 3phase supply but all the 6 relay coils get DC voltage and their common point disconnects from the NC and moves on to the NO points there by providing logic high at pin2 of 555 timer U1 i.e. that is kept on monostable mode. When any push button across the relay is pressed, it disconnects that relay and in the process in common contacts moves to the NC position. It provides a logic low at trigger pin of 555 timer to develop an output that brings the U3 555 timer which is used in astable mode, for its reset pin to high such that the astable operation takes place at its output which is also indicated by flashing D11 LED. If the fault is off temporary in nature i.e. if the push button pressed is released immediately the U1 monostable disables U3. The output then goes to zero in the event of any push button kept pressed for a longer duration. The monostable output provides a longer duration active situation for U3 astable timer, the output of which charges capacitor C13 through R11 such that the output of the comparator goes high so that it drives the relay to disconnect the three phase load.

Components used

Transformer

A transformer is a static electrical device that uses inductive coupling between its winding circuits to transfer energy. Due to a varying primary winding current, a varying magnetic flux is generated in the core of the transformer which is then

induced to the secondary winding. Due to this varying magnetic flux, a varying electromotive force (EMF) or voltage is generated in the secondary winding. Transformers can vary the relative voltages of the circuit or isolate them, or both.




Figure 3: Transformer with Flux Linkages

Voltage regulator

A voltage regulator is so designed that it automatically maintains a constant voltage level. A voltage regulator can be designed as a simple "feed-forward" circuit or can include negative feedback control loops. It can consist of an electromechanical mechanism.




Figure 4: Voltage regulator IC

555 Timer

The 555 Timer IC is an integrated circuit (chip) that is widely used in several multivibrator and timer applications. The design of the IC was given by Hans R. Camenzind in 1970 which was later brought to the market in 1971 by Signetics (later acquired by Philips). This chip provides timing mechanism which is used to differentiate between temporary and permanent faults. The timing of the IC can be varied by varying the value of the resistance and capacitance used along with it.

$$T = (R_1 + R_2) C$$





Figure 5: 555 Timer with PIN diagram

Relay

A relay can be defined as an electrically operated switch. In many relays an electromagnet is used to operate a switching mechanism mechanically, but many other operating principles are also used. Relay controls the circuit with a low-power signal. They also provide electrical isolation between control and the controlled circuit. Both DC and AC relays are used in this system.




Figure 6: Electromagnetic Relay

Conclusion

This three phase fault analysis system is built using six single phase transformers out of which three are wired in star in star out configuration, and the rest 3 are connected in delta connections. The input to the transformers is 220 volt and output is 12 volt. For introducing faults on the low voltage side, set of switches are used that create LL, LG, and 3L faults. The supply returns to the load in the case of a short duration fault and is referred as a temporary trip while long duration disconnection of supply and load shall result in a permanent trip.

References

1. H. Akagi, H.E. Watanabe, and M. Aredes, "Instantaneous power theory and applications to power conditioning", Wiley-IEEE Press, pp. 43-105, (2007).
2. A.M. Stankovic, "Analysis of Asymmetrical Faults in Power Systems Using Dynamic Phasors", IEEE Transactions on Power Systems, Vol. 15, pp. 1062-1068, (2000).
3. V. Gamit, V . Karode, K. Mistry, P. Parmar, and A. Chaudhari, "Fault Analysis on Three Phase System by Auto Reclosing Mechanism", IJRET: International Journal of Research in Engineering and Technology, Vol.4, No. 5, (2015).
4. S. Manivannan, S. Veerakumar, P. Karuppusamy, and A. Nandhakumar, "Performance Analysis of Three Phase Voltage Source Inverter Fed Induction Motor Drive with Possible Switching Sequence Execution in SVPWM", International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering, Vol. 3, No. 6, June (2014).
5. M.S. Morey, A. Ghodmare, V . Khomane, A. Singh, J. Dawande, and S. Ali Iqbal Shaikh, "Microcontroller Based Three Phase Fault Analysis for Temporary and Permanent Fault", International Research Journal of Engineering and Technology (IRJET), Vol. 02, No. 01, March (2015).